

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION



Report Of Chemical Examination Of Water

NAME - Creative Public School

ADDRESS - Ravet, pune

NO-WS / LAB / 888 / 2022

DATE - 27 / 01 / 2022


DATE OF RECEIPT - 25 / 01 / 2022

DATE OF EXAMINATION - 26 / 1 / 2022

No.	Tests	I. S Standard for Drinking Water	Results mg/lit	Results mg/lit	Conclusion
1	Turbidity	5 N.T.U max	0.71 NTU		
2	pH	6.5 to 8.5	7.61		
3	Total Hardness (AS CaCo3)	300 mg/lit max	32 mg/l		
4	Chloride	250 mg/lit max	8 mg/l		
5	Calcium	75 mg/lit max	6.41 mg/l		

NOTE-SAMPLE NOT DRAWN BY THIS LABORATORY

COPY TO-


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION



No-WS/Lab/ **886/2022**

Date - **25 / 01 / 2022**

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

NAME - **Creative Public School**

DATE OF EXAMINATION - **25/01/2022**

ADDRESS - **Ravet, pune**

NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN / 100ml		REMARK
			Coliforms	E. Coli	
1	water sample	Nil	18 ⁺ /100ml	-	Non potable
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					

CHIEF CHEMIST
 Water Treatment Plant
 Pimpri Chinchwad Municipal Corp.
 Nigai, Pune 44


NOTE-SAMPLE NOT DRAWN BY THIS LABORATORY



Pimpri Chinchwad Municipal
Corporation, Pimpri 411 018
Health head office
Outward no.HHO/5/WS/Jan/2022
Date - 3/1/2022

SCHOOL SANITATION CERTIFICATE

This is to certify that the B ward Health Department of Pimpri Chinchwad Municipal Corporation, Pimpri, Pune-411 018 has inspected the premise of **CREATIVE PUBLIC School Ravet, Pune 412 101 Dt 27/1/2022** and found that the sanitation requirements for educational institution are as per the norms of Pimpri Chinchwad Municipal Corporation, Development Control Rules. This certificate is valid for the period of **one year from the date of issue.**


(Dr. K. Anil Roy)
Medical Officer of Health
Pimpri Chinchwad Municipal
Corporation, Pimpri 411 018

